

# VOC Content Test Certificate

Monday 8<sup>th</sup> July 2024


Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park, NSW, 2164, Australia)  
Product Name: Sikaflex 11 FC Purform  
Date Tested: 13<sup>th</sup> January 2020 (Tested by Eurofins Product Testing A/S – Denmark)  
Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Sikaflex 11 FC Purform</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>&lt;1 gram per litre as VOC content per material</b>
<i>We hereby certify Sikaflex 11 FC Purform is below the VOC Content limits of chosen category specified by Green Star Design &amp; As Built, Green Building Council of Australia.</i>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue Date: 8/07/2024

Expiry date: 8/07/2026

P24070025